



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL SUB DISTRICT LABORATORY**  
**IRINJALAKUDA,THRISSUR**  
**(NABL Recognized Sub Divisional Level Government Drinking Water Testing Laboratory)**  
**(Certificate No: NABL -DWT-00984)**  
**Telephone No - 0480-2997761, E-mail - kwa.qcsd.ijk@gmail.com**

## Test Report

Test Report. No : KWA/QCSDL/IJK-TSR/S-005728/2025

Report Date : 15/12/2025

*NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.*

Reviewed by:

Authorized By

## Technical Manager

Issue Date 10/01/2023	Issue No: 2	KWA/QCSDL/LIK-TSR/R.No:6
Rev.No: 01	Rev Date: 26-04-2023	Quality Control & Sanitary District Labo Page 1 of 1 Kerala Water Authority Kerala, India - 660 121





**KERALA WATER AUTHORITY  
QUALITY CONTROL SUB DISTRICT LABORATORY  
IRINJALAKUDA THRISSUR**

Telephone No - 0480-2997761, E-mail - [kwa.qcsd.jjk@gmail.com](mailto:kwa.qcsd.jjk@gmail.com)

## Test Report

Test Report. No : KWA/QCSDL/IJK-TSR/S-005728/2025

Report Date : 15/12/2025

Customer Name & Address <b>CKMNSS SENIOR SECONDARY SCHOOL SAMPLE 1 R B ROAD 680307</b>		1. Date of Receipt : 08/12/2025 2. Sampling done by : The Customer 3. UID No. of Sample : KWA/QCSDL/IJK-TSR/S-005728/2025 4. Source of Sample : OPEN WELL 5. Sample condition : Good 6. Name of sample : Drinking Water 7. Purpose of test : Commercial 7. Sample Quantity : 2 Litre 8. Test Performing Dates From : 08/12/25 To : 08/12/25
Sl. No.	Characteristics	Unit
1	Electrical Conductivity	(micro mhos/cm)
2	Iron (as Fe)	(mg/litre)
3	Nitrate (as NO <sub>3</sub> )	(mg/litre)

Remarks:-

*NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.*

Reviewed by:

Authorized By:  
Technical Manager,  
Quality Control Sub District Laboratory  
Kerala Water Authority  
Trinjala - 680 121

Issue Date: 10/01/2023 Issue No: 00 KWA/QCSDL/IJK-TSR/R.NO:6  
 Rev. No: 00 Rev Date: 00 Page 1 of 1



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL SUB DISTRICT LABORATORY**  
**IRINJALAKUDA,THRISSUR**

Telephone No - 0480-2997761, E-mail -kwa.qcsd.ijk@gmail.com

**Test Report**

Test Report. No : KWA/QCSLD/IJK-TSR/S-005728/2025

Report Date : 15/12/2025

<b>Customer Name &amp; Address</b>		<b>1. Date of Receipt : 08/12/2025</b>		
<b>CKMNSS SENIOR SECONDARY SCHOOL SAMPLE 1 R B ROAD 680307</b>		<b>2. Sampling done by : The Customer</b>		
		<b>3.UID No.of Sample :KWA/QCSLD/IJK-TSR/S-005728/2025</b>		
		<b>4. Source of Sample : OPEN WELL</b>		
		<b>5. Sample condition : Good</b>		
		<b>6. Name of sample : Drinking Water</b>		
		<b>7. Purpose of test : Commercial</b>		
		<b>8. Sample Quantity : 100 ml</b>		
		<b>9. Test Performing Dates</b>		
		<b>From : 08/12/25</b>		<b>To :10/12/25</b>
Sl. No.	Parameters	Acceptable limits as per-IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 (Reaffirmed 2021)	<b>NOT DETECTED</b>
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 (Reaffirmed 2021)	<b>NOT DETECTED</b>

**Remarks:-**

*NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.*

*John*  
Reviewed by:

*Geeta*  
Authorized By:

*Technical Manager,*  
Quality Control Sub.District Laboratory  
Kerala Water Authority  
Irinjalakuda - 680 121

Issue Date: 10/01/2023	Issue No: 300500	KWA/QCSLD/IJK-TSR/R.NO:6
Rev.No: 00	Rev Date: 00	Page 1 of 1

