



KERALA WATER AUTHORITY
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
QUALITY CONTROL SUB DIVISION, THRISSUR – 680 005
Ph: 0487-2338380

Date :

BASIC WATER ANALYSIS REPORT
on Flood effected water sources

Name: Jose . E.V. Fr Paul chittilappilly school
Administrator
Place : Engandiyur

Sl.No	Characteristics	Unit	Limit	Value
1	Colour	Coloured	Colourless	
2	Odour	Agreeable	Not agreeable	
3	Turbidity	NTU	1 to 5	0.3
4	pH		6.5 to 8.5	7.5
5	Electrical Conductivity	micro mhos/cm		315
6	Total dissolved Solids	mg/litre	500 to 2000	243
7	Residual Chlorine	mg/litre	0.2 to 1	NIL
8	Ammonia Nitrogen	mg/litre		NIL
9	Others	mg/litre		



[Signature]
Chemist/ Assi. Engineer