

Office of the Asst. Divisional Officer,
Fire & Rescue Services, Thrissur.

No: A- 5038/2013

Dtd. 10/10/2013

NO OBJECTION CERTIFICATE

The two L.P.G Cylinders serial connection arrangements in the Chemistry Laboratory of **Fr. Paul Chittilappilly Memorial Public School** in Sy.No: 342/8, in Engandiyur Village, Engandiyur Panchayath, Chavakkad Thaluk, Thrissur district owned by **The Principal, Fr. Paul Chittilappilly Memorial Public School, Engandiyur, Thrissur** was inspected by me on 10/10/2013 in Fire Safety point of view under Petroleum Act & Rules. Adequate first aid fire protection arrangements have been provided in the Chemistry Laboratory of the above said school at the time of my inspection.

The first aid fire fighting equipments provided in the Chemistry Laboratory is considered sufficient to use 2 Nos: (Two numbers only) L.P.G. Cylinders in series connection. Therefore this department has No Objection in using two L.P.G. cylinders in the Chemistry Laboratory of the school mentioned above.

This certificate is issued for the affiliation from CBSE only.



MANAGER

**Fr. PAUL CHITTIAPPILLY MEMORIAL
PUBLIC SCHOOL, CBSE/AH/931123
ENGANDIYUR, THRISSUR-680615
Ph: 2294483**



**PRINCIPAL
Fr. PAUL CHITTIAPPILLY
PUBLIC SCHOOL, CBSE/AH/931123
ENGANDIYUR, THRISSUR-680615
Ph: 2294483**


**Asst. Divisional Officer,
Fire & Rescue Services,
Thrissur.**

**The Principal,
Fr. Paul Chittilappilly Memorial Public School,**



Your Safety is Our Priority ISO 9001:2015
Manufacturing / Projects / AMC
An ISO 9001:2015 Certified Company

Quality
Reliability
Dependability



GST32CNITS6982G1Z1

Date: 22-06-2018

INSPECTION AND TEST CERTIFICATE

THIS IS TO CERTIFY THAT THE UNDERMENTIONED EXTINGUISHERS BELONGING TO
FATHER PAUL CHITILAPPALLY MEMORIAL PUBLIC SCHOOL, EGANADIYUR, THRISSUR
WERE INSPECTED AND EXTINGUISHERS TESTED AS PER DETAILS GIVEN BELOW AND
TEST RESULTS ARE INDICATED AGAINST EACH

TYPE OF EXTINGUISHER: ABC.2KG - 02Nos

INSTALLATION DATE : 22.06.2018

DUE DATE : 21.06.2019

MANAGER

PRINCIPAL

Ft. PAUL CHITILAPPALLY MEMORIAL
PUBLIC SCHOOL, CBSE/Aff/931128
ENGANDIYUR, THRISSUR-680615
Ph: 2294483

Ft. PAUL CHITILAPPALLY MEMORIAL
PUBLIC SCHOOL, CBSE/Aff/931128
ENGANDIYUR, THRISSUR-680615
Ph: 2294483

Authorized Signature:



USHA FIRE TECH
ISO 9001:2015
Company
NFPA MEMBER

USHA FIRE TECHNOLOGY PVT.LTD.

TC 30/11/4, Shobhas, Ambalathumukku, Pettah PO, Trivandrum, Kerala

+91 9048413450, +91 9562262000 | ushafire.safety@gmail.com | www.ushafiretech.in | 1800 3000 9205

REF : CFIL/2015-16/535

TO WHOMSOEVER IT MAY CONCERN

This is to certify that Ceasefire Industries Ltd has been supplying fire fighting equipments with frequent service and tips to handle the equipments. Also render proper demonstration on how to combat fire in the event of a mishap to Fr. Paul Chittilapilly Memorial Public School, Engandiyur, Thrissur Dt Pin 680615, CBSE/AFF./931128

In the view of the above, it is certified that Fr. Paul Chittilapilly Memorial Public School, Engandiyur, Thrissur Dt Pin 680615, CBSE/AFF./931128. is equipped with Three Numbers of ABC MAP 90 2 Kg fire extinguishers are in good working condition .

Yours truly,

Date 26/6/2015

For Ceasefire Industries Ltd



Authorized Signatory

**MANAGER**

Fr. PAUL CHITILAPILLY MEMORIAL
PUBLIC SCHOOL, CBSE/Aff/931128
ENGANDIYUR, THRISSUR-680615
Ph: 2294483

PRINCIPAL

Fr. PAUL CHITILAPILLY MEMORIAL
PUBLIC SCHOOL, CBSE/Aff/931128
ENGANDIYUR, THRISSUR-680615
Ph: 2294483





ഏങ്ങണ്ടിയൂർ ഗ്രാമപഞ്ചായത്ത് കാര്യാലയം

പി.ഒ. ഏങ്ങണ്ടിയൂർ പിൻ-680615

തൃശ്ശൂർ ജില്ല, ഫോൺ: 0487-2290274

Email id:-engandiyurgp@gmail.com

നമ്പർ : A3/4251/19

തീയതി-11.07.2019

പ്രേഷകൻ

സെക്രട്ടറി,

ഏങ്ങണ്ടിയൂർ ഗ്രാമ പഞ്ചായത്ത്.

സ്വീകർത്താവ്

മാനേജർ,

ഫാ. പോൾ ചിറ്റിലപ്പിള്ളി മെമ്മോറിയൽ പബ്ലിക് സ്കൂൾ,

ഏങ്ങണ്ടിയൂർ

സർ,

വിഷയം: ഏങ്ങണ്ടിയൂർ ഗ്രാമപഞ്ചായത്ത്- സ്കൂൾ കെട്ടിടത്തിന് ഫയർ & റെസ്ക്യൂ സർഫിക്കറ്റ് ലഭ്യമാക്കുന്നത് - സംബന്ധിച്ച്

സൂചന: 1)അങ്ങയുടെ 04/07/2019 ലെ ഏ3/4251/19 നമ്പർ കത്ത്.

2)അസി.എഞ്ചിനീയറുടെ 11.07.2019 ലെ ഏ3/4614/19 നമ്പർ റിപ്പോർട്ട്.

മേൽ വിഷയം സംബന്ധിച്ച് സൂചന (1) പ്രകാരമുള്ള അപേക്ഷ പരിശോധിച്ചതിൽ ടീ സ്കൂൾകെട്ടിടത്തിന്റെ അടിത്തറ വിസ്തീർണ്ണം 274.45 ച.മീ, കൂടാതെ കെട്ടിടത്തിന്റെ ഉയരം 15 മീറ്ററിൽ കുറവും ആയതിനാൽ റൂൾ 56(5) i,ii പ്രകാരം ഫയർ എൻ.ഒ.സി ആവശ്യമില്ല എന്ന് അസി. എഞ്ചിനീയർ റിപ്പോർട്ട് ചെയ്തിട്ടുള്ള വിവരം അറിയിച്ചു കൊള്ളുന്നു.

വിശ്വസ്തതയോടെ.


A3


MANAGER


PRINCIPAL
Fr. PAUL CHITILAPPILY MEMORIAL
PUBLIC SCHOOL, CBS
ENGANDIYUR, THRISSUR-680615


SECRETARY

Fr. PAUL CHITILAPPILY MEMORIAL PUBLIC SCHOOL, CBS Engandiyur Grama Panchavath
ENGANDIYUR, THRISSUR-680615